



Drytac Corporation
5601 Eastport Boulevard
Richmond, VA 23231
Tel: (804) 222-3094
Fax: (804) 226-2330

www.drytac.com

THIRD PARTY CERTIFICATION

Issue Date: June 13, 2012

This is to certify that Lintec Digital Window Graphics UV film has been tested in accordance with the following safety standard for flame spread and smoke density and meets the requirements for "Class A" Flame Spread.

ASTM Designation E84-12,"Standard Method of Test for Surface Burning Characteristics of Building Materials"

QAI Laboratories
Test Report No. RJ1886-3

These test results are not transferable and may not be relevant or applicable to real life applications. Therefore, Drytac® strongly recommends and other regulatory entities may require additional testing to determine the suitability for any specific end application. Refer to Drytac® Terms and Conditions of Sale at www.drytac.com for additional liability limitations.

This certificate is the property of Drytac® Corporation. This certificate and all copies should be returned to Drytac® upon request.