

## THIRD PARTY CERTIFICATION

|                                   |   |
|-----------------------------------|---|
| <b>PRODUCT NAME:</b>              | Protac™ Canvastex™                                      |
| <b>PRODUCT PART NUMBER:</b>       | ICX   |
| <b>STANDARD:</b>                  | EN 13036-4  |
| <b>PENDULUM TEST VALUE (PTV):</b> | Dry: 65<br>Wet: 31                                      |
| <b>CLASSIFICATION:</b>            | Dry: Low Slip Potential<br>Wet: Moderate Slip Potential |
| <b>ISSUE DATE:</b>                | May 2020  |
| <b>TEST REPORT REFERENCE:</b>     | UK202039-15091  |

**For more information, performance and warranty guide lines please contact your local Drytac office.**

These test results are not transferable and may not be relevant or applicable to real life applications. Therefore, Drytac<sup>®</sup> strongly recommends and other regulatory entities may require additional testing to determine the suitability for any specific end application. Refer to Drytac<sup>®</sup> Terms and Conditions of Sale at [www.drytac.com](http://www.drytac.com) for additional liability limitations. This certificate is the property of Drytac<sup>®</sup> Corporation. This certificate and all copies should be returned to Drytac<sup>®</sup> upon request.

### Europe

Filwood Road,  
Fishponds,  
Bristol, BS16 3RY,  
United Kingdom  
[bristol@drytac.com](mailto:bristol@drytac.com)  
Tel: +44 (0) 117 958 6500

### Canada

30 Driver Road,  
Brampton,  
Ontario, L6T 5V2,  
Canada  
[toronto@drytac.com](mailto:toronto@drytac.com)  
Tel: +1 800.353.2883

### USA

5401-B Eubank Road,  
Sandston,  
Virginia, 23150,  
USA  
[customerservice@drytac.com](mailto:customerservice@drytac.com)  
Tel: +1 800.280.6013