

THIRD PARTY CERTIFICATION

PRODUCT NAME:	Protac™ Sheentex™
PRODUCT PART NUMBER:	PS-TM
STANDARD:	EN 13036-4
PENDULUM TEST VALUE (PTV):	Dry: 68 Wet: 41
CLASSIFICATION:	Dry: Low Slip Potential Wet: Low Slip Potential
ISSUE DATE:	May 2020
TEST REPORT REFERENCE:	UK202039-15092

For more information, performance and warranty guide lines please contact your local Drytac office.

These test results are not transferable and may not be relevant or applicable to real life applications. Therefore, Drytac[®] strongly recommends and other regulatory entities may require additional testing to determine the suitability for any specific end application. Refer to Drytac[®] Terms and Conditions of Sale at www.drytac.com for additional liability limitations. This certificate is the property of Drytac[®] Corporation. This certificate and all copies should be returned to Drytac[®] upon request.

Europe

Filwood Road,
Fishponds,
Bristol, BS16 3RY,
United Kingdom
bristol@drytac.com
Tel: +44 (0) 117 958 6500

Canada

30 Driver Road,
Brampton,
Ontario, L6T 5V2,
Canada
toronto@drytac.com
Tel: +1 800.353.2883

USA

5401-B Eubank Road,
Sandston,
Virginia, 23150,
USA
customerservice@drytac.com
Tel: +1 800.280.6013