

SLIP RATING - THIRD PARTY CERTIFICATION

PRODUCT NAME:	FloorTac™ Emerytex® White RB
PRODUCT PART NUMBER:	PFTE
STANDARD:	ASTM E303; Latex Printed Sample
PENDULUM TEST VALUE (PTV):	Dry: 65 Wet: 26
CLASSIFICATION:	Dry: Low Slip Potential Wet: Moderate Slip Potential
ISSUE DATE:	June 2020
TEST REPORT REFERENCE:	UK202369-18087

For more information, performance and warranty guide lines please contact your local Drytac office.

These test results are not transferable and may not be relevant or applicable to real life applications. Therefore, Drytac® strongly recommends and other regulatory entities may require additional testing to determine the suitability for any specific end application. Refer to Drytac® Terms and Conditions of Sale at www.drytac.com for additional liability limitations. This certificate is the property of Drytac® Corporation. This certificate and all copies should be returned to Drytac® upon request.

DRYTAC[®]